

SUNNYHILL WATER SUPPLY

2015 JUN 25 PM 2:38

Annual Drinking Water Quality Report

Sunnyhill Water Association, Inc.**PWS #MS0570014****June 28, 2015****Is my water safe?**

We are pleased to present this year's Annual Water Quality Report (Consumer Confidence Report) as required by the Safe Drinking Water Act (SDWA). This report is designed to provide details about where your water comes from, what it contains, and how it compares to standards set by regulatory agencies. This report is a snapshot of last year's water quality. We are committed to providing you with information because informed customers are our best allies.

Do I need to take special precautions?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Water Drinking Hotline (800-426-4791).

Where does my water come from?

Our water source is from 5 wells using water from the Miocene Aquifer.

Source water assessment and its availability

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identified potential sources of contamination. The general susceptibility rankings assigned to each well of this system are provided immediately below. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for Sunnyhill Water Association have received a moderate susceptibility ranking to contamination.

Why are there contaminants in my drinking water?

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's (EPA) Safe Drinking Water Hotline (800-426-4791).

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity: microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban stormwater runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses; organic Chemical Contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems; and radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

How can I get involved?

If you have questions about this report or concerning our water utility, please contact Charles Schilling, Office Manager, at 601-249-3502. We want our valued customers to be informed about their water utility. If you want to learn more, please attend our monthly board meeting, which is held at 6:00 PM on the third Monday of each month at the water office at 612 Delaware Avenue, Suite 4, McComb, MS.

Description of Water Treatment Process

Your water is treated by filtration and disinfection. Filtration removes particles suspended in the source water. Particles typically include clays and silts, natural organic matter, iron and manganese, and microorganisms. Your water is also treated by disinfection. Disinfection involves the addition of chlorine or other disinfectants to kill bacteria and other microorganisms (viruses, cysts, etc.) that may be in the water. Disinfection is considered to be one of the major public health advances of the 20th century.

Additional Information for Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Sunny Hill Water Association, Inc is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Water Quality Data Table

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of contaminants in water provided by public water systems. The table below lists all of the drinking water contaminants that we detected during the calendar year of this report. Although many more contaminants were tested, only those substances listed below were found in your water. All sources of drinking water contain some naturally occurring contaminants. At low levels, these substances are generally not harmful in our drinking water. Removing all contaminants would be extremely expensive, and in most cases, would not provide increased protection of public health. A few naturally occurring minerals may actually improve the taste of drinking water and have nutritional value at low levels. Unless otherwise noted, the data presented in this table is from testing done in the calendar year of the report. The EPA or the State requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not vary significantly from year to year, or the system is not considered vulnerable to this type of contamination. As such, some of our data, though representative, may be more than one year old. In this table you will find terms and abbreviations that might not be familiar to you. To help you better understand these terms, we have provided the definitions below the table.

| Contaminants | MCLG or MRDLG | MCL, TT, or MRDL | Your Water | Range | | Sample Date | Violation | Typical Source |
|---|---------------------|------------------------|---------------|-------|------|----------------|-----------|--|
| | | | | Low | High | | | |
| Disinfectants & Disinfectant By-Products | | | | | | | | |
| (There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants) | | | | | | | | |
| Chlorine (as Cl ₂) (ppm) | 4 | 4 | 2.1 | 1.65 | 2.47 | 2014 | No | Water additive used to control microbes |
| Inorganic Contaminants | | | | | | | | |
| Cyanide [as Free CN] (ppb) | 200 | 200 | 15 | 15 | 15 | 2014 | No | Discharge from plastic and fertilizer factories; Discharge from steel/metal factories |
| Antimony (ppb) | 6 | 6 | 0.5 | 0.5 | 0.5 | 2014 | No | Discharge from petroleum refineries; fire retardants; ceramics; electronics; solder; test addition. |
| Arsenic (ppb) | 0 | 10 | 0.5 | 0.5 | 0.5 | 2014 | No | Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes |

| | | | | | | | | |
|--------------------------------------|-----|-----|--------|--------|--------|------|----|---|
| Barium (ppm) | 2 | 2 | 0.0068 | 0.0068 | 0.0068 | 2014 | No | Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits |
| Beryllium (ppb) | 4 | 4 | 0.5 | 0.5 | 0.5 | 2014 | No | Discharge from metal refineries and coal-burning factories; Discharge from electrical, aerospace, and defense industries |
| Cadmium (ppb) | 5 | 5 | 0.5 | 0.5 | 0.5 | 2014 | No | Corrosion of galvanized pipes; Erosion of natural deposits; Discharge from metal refineries; runoff from waste batteries and paints |
| Chromium (ppb) | 100 | 100 | 5 | 5 | 5 | 2014 | No | Discharge from steel and pulp mills; Erosion of natural deposits |
| Fluoride (ppm) | 4 | 4 | 0.436 | 0.436 | 0.436 | 2014 | No | Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories |
| Selenium (ppb) | 50 | 50 | 2.5 | 2.5 | 2.5 | 2014 | No | Discharge from petroleum and metal refineries; Erosion of natural deposits; Discharge from mines |
| Thallium (ppb) | 0.5 | 2 | 0.5 | 0.5 | 0.5 | 2014 | No | Discharge from electronics, glass, and Leaching from ore-processing sites; drug factories |
| Mercury [Inorganic] (ppb) | 2 | 2 | 0.5 | 0.5 | 0.5 | 2014 | No | Erosion of natural deposits; Discharge from refineries and factories; Runoff from landfills; Runoff from cropland |
| Nitrate [measured as Nitrogen] (ppm) | 10 | 10 | 0.08 | 0.08 | 0.08 | 2014 | No | Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits |
| Nitrite [measured as Nitrogen] (ppm) | 1 | 1 | 0.02 | 0.02 | 0.02 | 2014 | No | Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits |
| Radioactive Contaminants | | | | | | | | |
| Uranium (ug/L) | 0 | 30 | 0.5 | 0.5 | 0.5 | 2012 | No | Erosion of natural deposits |
| Volatile Organic Contaminants | | | | | | | | |
| 1,2,4-Trichlorobenzene (ppb) | 70 | 70 | 0.5 | 0.5 | 0.5 | 2014 | No | Discharge from textile-finishing factories |
| cis-1,2-Dichloroethylene (ppb) | 70 | 70 | 0.5 | 0.5 | 0.5 | 2014 | No | Discharge from industrial chemical factories |

[illegible]

| | | | | | | | |
|--|-----|-----|--------|------|---|----|--|
| Lead - action level at consumer taps (ppb) | 0 | 15 | 2.3 | 2012 | 0 | No | Corrosion of household plumbing systems; Erosion of natural deposits |
| Copper - action level at consumer taps (ppm) | 1.3 | 1.3 | 0.0633 | 2012 | 0 | No | Corrosion of household plumbing systems; Erosion of natural deposits |

| Unit Descriptions | |
|-------------------|--|
| Term | Definition |
| ug/L | ug/L : Number of micrograms of substance in one liter of water |
| ppm | ppm: parts per million, or milligrams per liter (mg/L) |
| ppb | ppb: parts per billion, or micrograms per liter (ug/L) |
| NA | NA: not applicable |
| ND | ND: Not detected |
| NR | NR: Monitoring not required, but recommended. |

| Important Drinking Water Definitions | |
|--------------------------------------|---|
| Term | Definition |
| MCLG | MCLG: Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety. |
| MCL | MCL: Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology. |
| TT | TT: Treatment Technique: A required process intended to reduce the level of a contaminant in drinking water. |
| AL | AL: Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow. |
| Variances and Exemptions | Variances and Exemptions: State or EPA permission not to meet an MCL or a treatment technique under certain conditions. |
| MRDLG | MRDLG: Maximum residual disinfection level goal. The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants. |
| MRDL | MRDL: Maximum residual disinfectant level. The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants. |
| MNR | MNR: Monitored Not Regulated |
| MPL | MPL: State Assigned Maximum Permissible Level |

For more information please contact:

Contact Name: Charles Schilling
Address:
612 Delaware Ave. Suite 4
McComb, MS 39648
Phone: (601) 249-3502
Fax: (601) 684-8230
E-Mail: sunnyhillwateras@bellsouth.net